

MAURITIAN
STANDARD

MS ISO
5149-3:2014

First edition
2018-09-29

**Refrigerating systems and heat
pumps — Safety and
environmental requirements**

Part 3:

Installation site

ICS 27.080; 27.200



**Mauritius Standards Bureau
Moka**

National foreword

This Mauritian Standard is identical with the International Standard **ISO 5149-3:2014**, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 3: Installation site*. It was adopted by the Mauritius Standards Bureau on the recommendation of the **Environmental Management, Tourism & Related Services Standards Committee** and approval of the **Standards Council** on 31 August 2018. It was notified in the Government Gazette on **29 September 2018***

For the purpose of this standard changes should be made as specified in National Annex A.

***General Notice No. 1400 of 2018.**



COPYRIGHT PROTECTED DOCUMENT

© MSB 2018

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without permission in writing from Mauritius Standards Bureau at the address below

*Mauritius Standards Bureau
Villa Road
Moka
Mauritius*

Telephone + (230) 433 3648
Fax + (230) 433 5051/ 433 5150
E-mail msb@intnet.mu

Contents

	Page
Foreword	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Location of refrigerating equipment	1
4.1 General.....	1
4.2 Refrigerating equipment located in the open air.....	2
4.3 Refrigerating equipment located in a machinery room.....	2
4.4 Refrigerating equipment located in the occupied space.....	2
4.5 Refrigerating equipment located in unoccupied areas not designated a machinery room.....	2
4.6 Refrigerating equipment located in a ventilated enclosure within an occupied space.....	2
4.7 Piping duct or shaft.....	2
5 Machinery rooms	2
5.1 Occupancy of machinery rooms and special machinery rooms.....	2
5.2 Venting from or through the machinery room.....	3
5.3 Combustion equipment and air compressors.....	3
5.4 Open flame.....	3
5.5 Storage.....	3
5.6 Remote emergency switch.....	3
5.7 Exterior openings of the machinery room.....	3
5.8 Piping and ducting.....	4
5.9 Normal lighting.....	4
5.10 Emergency lighting.....	4
5.11 Dimensions and accessibility.....	4
5.12 Doors, walls, and ducts.....	4
5.13 Ventilation.....	5
5.14 Machinery rooms for flammable refrigerants (groups A2L, A2, B2L, B2, B3, and A3).....	6
6 Requirements for alternative provisions	7
6.1 General.....	7
6.2 Occupied space.....	7
6.3 Ventilation.....	7
6.4 Safety shut-off valves.....	9
7 Electrical installations	9
7.1 General requirements.....	9
7.2 Main power supply.....	10
7.3 Electrical equipment in machinery rooms in which a refrigerating system contains class 2L flammability refrigerants.....	10
8 Safety alarms	10
8.1 General.....	10
8.2 Alarm system power.....	10
8.3 Alarm system warning.....	10
8.4 Additional alarm system requirements for R-717 systems with charges above 4 500 kg.....	11
9 Detectors	11
9.1 General.....	11
9.2 Location of detectors.....	11
9.3 Function of the detector.....	11
9.4 Type and performance of a detector.....	11
9.5 Installation.....	12
10 Instruction manuals, notices, and inspections	12
10.1 Instruction manual.....	12
10.2 Warning notice.....	12

10.3	Visual inspection of site.....	13
10.4	Maintenance of the site.....	13
11	Heat sources and temporary high temperatures located at the site	13
National Annex A.....		14
Bibliography		15

PREVIEW

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 1, *Safety and environmental requirements for refrigerating systems*.

ISO 5149-3, together with ISO 5149-1, ISO 5149-2, and ISO 5149-4, cancels and replaces ISO 5149:1993, which has been technically revised.

ISO 5149 consists of the following parts, under the general title *Refrigerating systems and heat pumps — Safety and environmental requirements*:

- *Part 1: Definitions, classification and selection criteria*
- *Part 2: Design, construction, testing, marking and documentation*
- *Part 3: Installation site*
- *Part 4: Operation, maintenance, repair and recovery*

PREVIEW

Refrigerating systems and heat pumps — Safety and environmental requirements —

Part 3: Installation site

1 Scope

This part of ISO 5149 is applicable to the installation site (plant space and services). It specifies requirements for the site for safety, which could be needed because of, but not directly connected with, the refrigerating system and its ancillary components.

This part of ISO 5149 is applicable to new refrigerating systems, extensions or modifications of existing systems, and for used systems being transferred to and operated on another site. This part of ISO 5149 also applies in the case of the conversion of a system for another refrigerant.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5149-1:2014, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 1: Definitions, classification and selection criteria*

ISO 5149-2:2014, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 2: Design, construction, testing, marking and documentation*

ISO 13850, *Safety of machinery — Emergency stop — Principles for design*

IEC 60204-1, *Safety of machinery — Electrical equipment of machines — General requirements*

IEC 60364-1, *Low-voltage electrical installations — Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-5, *Electrical installations of buildings — Part 5: Selection and erection of electrical equipment*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5149-1 apply.

4 Location of refrigerating equipment

4.1 General

Refrigerating equipment can be sited outside the building in the open air, in a designated machinery room, in occupied areas, or in unoccupied areas not designated as a machinery room.

The refrigerating equipment can be contained in a ventilated enclosure provided by the manufacturer. Requirements for this enclosure are given in ISO 5149-2:2014, 5.2.17.